



**Chesterfield County, Virginia  
Purchasing Department**

9901 Lori Road – P.O. Box 51 – Chesterfield, VA 23832-0001

Phone: (804) 748-1617 – Fax: (804) 717-6378 – Internet: [www.chesterfield.gov](http://www.chesterfield.gov)

**June 12, 2006**

**NOTICE OF ADDENDUM**

Invitation For Bids **#06-2156-9325** for **furnishing labor and equipment necessary for removing, dewatering, and disposing of liquid sludge from the primary digester which is located at the Falling Creek Wastewater Treatment Plant**, opening date **June 15, 2006 at 2:00 p.m.** Local Time Prevailing.

**ADDENDUM I**

This Addendum supplements, modifies, changes, deletes from, or adds to the original Invitation for Bid dated **May 26, 2006** for the project noted above and is herein made a part of the IFB and any resulting contract documents.

This Addendum consists of 1 page(s).

**Please make the following changes/clarifications/additions:**

**Following are questions received and the county's responses:**

1.     Question:     Does the county dewater digester sludge?  
       Answer:     The county does dewater our secondary digested sludge by means of belt filter press. It is all land applied for agricultural use as class "B" biosolids.
  
2.     Question:     Will the county be able to provide 480 volt; 200 amp; 3-phase temporary power?  
       Answer:     480 volt, 3 phase, 200 amp service is available. Maximum power cord would be 100'.
  
3.     Question:     Is the county expecting one lump-sum price for both digesters?  
       Answer:     Yes, the Total Bid shall include pricing for both digesters.

Please sign and return this addendum to the Purchasing Department, 9901 Lori Road, P. O. Box 51, Chesterfield, VA 23832-0001, **as this will be considered as part of bid. Bids, to include addenda or changes to a response, shall not be accepted via fax machine or by internet e-mail.**

COMPLETE LEGAL NAME OF BIDDER: \_\_\_\_\_

SIGNATURE: \_\_\_\_\_

DATE: \_\_\_\_\_

Jo Carol Mayton, CPPB  
Principal Contract Officer